

Declaration regarding the efficiency of a shower heat recovery unit

Kiwa Nederland B.V. hereby declares that of the shower heat recovery unit,

Type : **Recoh-vert V3 (douche pijp-wtw V3)**

Of : **Hei-tech B.V.**

In : **Emmen, The Netherlands**

of which a sample supplied and installed by Hei-tech has been tested according to the method described in NEN 5128 A1:2009, published 1 May 2009 and the correction letter of TNO 26 June 2009. The measurements have shown that the sample recovers the waste energy in the shower water with an efficiency of:

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
3	9.2	73	65.4	0.37
4, 5, 6	12.5	100	62.2	0.62

Apeldoorn, 7 April 2010



Ing. A.A. Slomp,
Product Manager,
Kiwa Nederland B.V.